





**Electrical Analysis Report With Harmonics**  
**Product : LED Flame Proof Flood Light 130W**

**Product: LED Flame Proof Flood Light 130W**

**Recording Start Date**      01/03/2016  
**Recording Duration**        5:00 (min:s)  
**Instrument ID**                Model C.A 8230 - 103247 1.6  
**Database File Name**        Trend HBG160\_1.dvb  
**Instrument Configuration**    Connection Type: Single-Phase



**Product : LED Flame Proof Flood Light 130W**



Graph - Total Harmonic Distortion - ATHD/VTHD


01-03-2016 - 14:50:00.000  
Value  
2.000 — V THD  
15.90 — A THD



Reg Office : 40/54, Kasi Estate 4th Street, Ashok Nagar, Chennai - 600083  
 Phone : 044-24710257 Email : vinwares@gmail.com Web Site : www.vinwares.com


**Product : LED Flame Proof Flood Light 130W**

Graph - Voltage(Vrms)




01-03-2016 - 14:50:07.000  
 Value  
 240.7 — V RMS

Graph - Current(Arms)




01-03-2016 - 14:50:00.000  
 Value  
 0.600 — A RMS

Graph - True Power(W)/Apparent Power(VA)/  
 Reactive Power(var)



01-03-2016 - 14:50:00.000  
 Value  
 132.8 — W1  
 -35.08 — var1  
 139.1 — VA1

Graph - Power Factor(PF)



01-03-2016 - 14:50:00.000  
 Value  
 0.955 — PF1